

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4475-0054:001

Page 1 of 1

CATEGORY: Ventilators (Smoke/Heat)

LISTEE: Lane-Aire Mfg., 2820 El Presidio Street, Carson, CA 90749
Contact: Donald Harms (213) 636-2324

DESIGN: Callaway Models SV5555, SV5566, SV5578, SV5596, SV55102 single door smoke and heat vent; Models SVDD66126, SVDD8080 and SVDD80152 double door smoke and heat vent. Unit is factory assembled ventilator with insulated curb and cover formed of 0.125" thick aluminum or 14 ga. cold-rolled steel; 6" high curb; chrome-vanadium torsion springs and lever arm covering opening mechanism, held in closed position by a listed fusible link. Refer to listee's data sheets for detailed product description and operational considerations.

INSTALLATION: In accordance listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and CSFM label.

APPROVAL: Listed as smoke and heat vent for use in areas required by code to provide smoke venting. Authority having jurisdiction should be consulted prior to installation.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

APRIL 27, 2001

*Listing Expires **June 30, 2002***

Authorized By:

BEN HO, Supervising Deputy
Program Manager